



NOTE:

1. Pipe size to be determined based on calculation (min 300Ø) submitted by applicant and approved by council.
2. Pipe sections are to be bedded on at least 100mm consolidated FCR or approved gravel.
3. Culvert Crossings are to be minimum of 4.88m length.
4. Pipe to be at a grade which allows smooth flow of water along table drain.
5. Asphalt or Concrete surfacing is not required when the road is unsealed.
6. Construction and road reinstatement in conjunction with issued Asset Permit Policy conditions.



**VEHICLE CROSSING,
PIPE CULVERT AND
ENDWALLS**
(Not To Scale)

DRAWN BY: J.G.

CHECKED : L.T.

DATE: 05.04.13

SD 001

REVISION	DATE	APPROVED
1.	15.11.2011	C.B.
2.	25.10.2012	C.B.
3.	05.04.2013	L.T.